Energy performance certificate (EPC)

39a Brook Street Blaenrhondda TREORCHY CF42 5SB	Energy rating	Valid until: Certificate	29 August 2033
		number:	2116-1361-0641-0803-7411
Property type			
Mid-terrace house			
Total floor area			
87 square metres			

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is C. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

9/20/23, 10:16 AM

Energy performance certificate (EPC) – Find an energy certificate – GOV.UK

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Very good
Roof	Pitched, 200 mm loft insulation	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, insulated (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 175 kilowatt hours per square metre (kWh/m2).

About primary energy use

How this affects your energy bills

An average household would need to spend £1,450 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £79 per year if you complete the suggested steps for improving this property's energy rating.

This is based on average costs in 2023 when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 7,848 kWh per year for heating
- 2,174 kWh per year for hot water

Impact on the environment

This property's current environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

Carbon emissions

An average household produces

	6 tonnes of CO2
This property produces	
	2.7 tonnes of CO2
This property's potential production	
	1.6 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

9/20/23, 10:16 AM Changes you could make

Do I need to follow these steps in order?

Step 1: Solar water heating	
Typical installation cost	
	£4,000 - £6,000
Typical yearly saving	
	£79
Potential rating after completing step 1	
	80 C
Step 2: Solar photovoltaic panels, 2.5 kWp	
Typical installation cost	
	£3,500 - £5,500
Typical yearly saving	
	£659
Potential rating after completing steps 1 and 2	
	90 B

Help paying for energy improvements

You might be able to get a grant from the Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name

Christopher Dixon

Telephone

07885637443

Email

cm_dixon@hotmail.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme ECMK

Assessor's ID ECMK302497

Telephone

0333 123 1418

Email

info@ecmk.co.uk

About this assessment

Assessor's declaration

No related party

Date of assessment

4 August 2023

Date of certificate

30 August 2023

Type of assessment

RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at <u>dluhc.digital-services@levellingup.gov.uk</u> or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number

9598-2056-7373-1317-1924 (/energy-certificate/9598-2056-7373-1317-1924)

Expired on

10 July 2023

<u>Help (/help)</u> <u>Accessibility (/accessibility-statement)</u> <u>Cookies (/cookies)</u> <u>Give feedback (https://forms.office.com/e/hUnC3Xq1T4)</u> <u>Service performance (/service-performance)</u>

OGL

All content is available under the <u>Open Government Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/)</u>, except where otherwise stated



<u>It (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework</u>